

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

**MEA 312-00-E
Report of Material and Equipment Acceptance Division**

Manufacturer – Jotul North America, 400 Riverside Street, Portland, Maine 04104.

Trade Name – JOTUL.

Product – Gas fired vented decorative fireplace appliances.

Pertinent Code Section(s) – 27-800, RS 14-2 (ANSI Z223).

Prescribed Test(s) - RS 14-6 (ANSI Z21.88).

Laboratory – Intertek Testing Services.

Test Report(s) – J20013599-231, dated August 10, 2000. J2003573-231 dated April 25, 2000, J99028608-231 dated January 13, 2000, J99017772-231 dated November 11, 1999, J99005154-231 dated June 2, 1999 and J98026742A dated December 17, 1998.

Description – Gas fired decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetics of a room. All of the below units are equipped with electric ignition.

Model No.	Description	Input Rating BTUH
GF100DV Nordic QT	Direct vent, freestanding space heater, piezo/standing pilot ignition system	14,500
Lillehammer	Direct vent, freestanding appliance, piezo/standing pilot ignition system	18,000
3DV II Allagash	Direct vent, freestanding appliance, piezo/standing pilot ignition system	24,000
GI-450DV Katadin	Direct vent, freestanding appliance, piezo/standing pilot ignition system	33,000
GF-600DV Firelight	Direct vent, freestanding appliance, piezo/standing pilot ignition system	40,000

Note: Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Recommendation - That the above described factory-built fireplaces, be accepted for use as supplemental heating and decorative purposes. The installation of the above described units shall be in accordance with manufacturer supplied instructions and all installations, uses and locations shall comply with Article 19 Solid Fuel Fireplace Stoves, and Room Heater and Article 2 Chimneys of the New York City Building Code and the UL Listing. Furthermore, the unit shall be vented in accordance with Section 27-856 of the Building Code. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 9/25/2000

Examined By S.M. Khan