



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 324-03-E Vol. 5

**Manufacturer:** Simplex Time Recorder Co., 100 Simplex Drive, Westminister, MA 01441-0001

**Trade Name(s):** TEPG-US

**Product:** Fire alarm equipment

**Pertinent Code Section(s):** Reference Standard RS-17 and Subchapter 17

**Prescribed Test(s):** UL 1480

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL Multiple Listing File S8347, issued October 8, 2003

**Description:** Fire alarm equipment as described below:

Model Number		Product
TEPG-US	Simplex (MEA 35-93-E, Vol. 12)	
The following products are found in UL File S8347, 10/9/2003, standard UL 1480		
T371-9101	4902-9716	Wall-mount Speaker, 25 or 70.7 Vrms input, red housing
T371-9102	4902-9717	Wall-mount Speaker, 25 or 70.7 Vrms input, white housing
T371-9103	4902-9721	Ceiling-mount Speaker, 25 or 70.7 Vrms input

**Terms and Conditions:** The above units are accepted on condition that:

1. All uses, locations and installations comply with the New York City Building Code, specifically Subchapter 17, and Reference Standard RS 17-3, as applicable including the NFPA as appropriate, the UL Listing, the manufacturer's instructions, the Fire Department Directives, and with the Department's Electrical Advisory Board of the City of New York.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance September 25, 2006  
Examined By 