



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 329-07-E

**Manufacturer:** The Delfield Company, 980 South Isabella Road, Mt. Pleasant, Michigan 48858

**Trade Name(s):** Delfied, Shelleyglas, Shelleysteel

**Product:** Commercial, electric cooking appliances  
MEA Index #150 – Cooking Appliances, Commercial

**Pertinent Code Section(s):** 27-771, 27-772, 27-777(f)

**Prescribed Test(s):** RS 14-6 (ANSI/UL 197)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** E64923, dated 3/26/07, 4/6/98, 4/27/00, 5/11/99, and 6/4/98.

**Description:** Electric, commercial cooking units comprising of resistance heating elements, fans, infinite controls, thermostatic controls, contactors, relays, switches, immersion heaters, thermal disc's and wire.

#### Product Covered:

**Food Wells:** Models 83, 84, 87, 88, 483 and 484 followed by 17 through 143. May be followed by -N, -B or 1 through 6 in various combinations.

**Food Warmers:** Models 145 with or without prefix V, with suffix 30 through 144, with or without suffix -28 through -34, with or without suffix -1, -2 or -3. Models K or S, followed by C, CI, CS, CI, H or RB. May be followed by 1 through 6, may be followed

**Terms and Conditions:** The above electric cooking units are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical, Building and Fire Codes.
2. Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.
3. Installation shall not obstruct access for operation and servicing.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 24, 2008

Examined By Shyam Prasad (SD)