



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 331-07-E

- Manufacturer:** Eiklor Flames Inc.
282 E. Pivot Point Road
Paoli, IN 47454
- Trade Name(s):** MOMBO® Gas Logs System
- Product:** Decorative gas appliance for installation in solid-fuel burning fireplaces -MEA Index #130-20 – Chimneys
- Pertinent Code Section(s):** Subchapter 14 and Reference Standard RS 14
- Prescribed Test(s):** RS 14 (ANSI Z21.60, ANSI.60A, ANSI Z21.60b)
- Laboratory:** CSA International
- Test Report(s):** 226847-1974479 test completed December 5, 2007

Description: A 0.035-inch thick 20-gauge stainless steel burner pan and a stainless steel burner tube of various lengths provided with or without simulated log kits for installation as decorative heating appliances for solid fuel burning fireplaces. Products' sizes and heating ratings are listed below:

MOMBO® Size	Heat Rating - Natural Gas (Btu/hr)
38"	115,000
42"	175,000
48"	200,000
52"	220,000
58"	300,000
64"	325,000
70"	400,000
75"	400,000

Clearances: Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Terms and Conditions: The above-described direct-vented, gas-fired appliances are accepted for decorative heating operation under the following conditions:

1. Such units are to provide supplemental heating and shall be direct-vented only.
2. Natural gas to be used for indoor installation only, with combustion air and required ventilation air provided.
3. Venting of the equipment is subject to Section 27-879 of the New York City Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance April 15, 2008
Examined By Donald [Signature]

