



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 341-03-E Vol. 4

**Manufacturer:** Honeywell International, Inc., 12 Clintonville Road, Northford, CT 06472

**Trade Name(s):** Fire-Lite Alarms, Notifier

**Product:** Fire Alarm Equipment

**Pertinent Code Section(s):** 27-968 through 27-977, RS 17

**Prescribed Test(s):** UL 864 and UL 1711

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File S2424, Project 05ME13749, issued January 26, 2006  
UL Multiple Listing, File No. S635, issued September 24, 1992, revised April 4, 2006

**Description:** Fire alarm equipment – watt-distributed audio panels manufactured for Notifier.

Model	Description
ACC-25/50DA	25/50 Watt voice alarm panel
ACC-25/50DAZS	25/50 Watt voice alarm panel
FireVoice 25/50DA	25/50 Watt voice alarm panel
FireVoice 25/50DAZS	25/50 Watt voice alarm panel
FC-MGM	Message Generator Module

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated September 25, 2006, F.P. Index #0609026.

**Terms and Conditions:** The above units are accepted on condition that:

1. All uses, applications and installations comply with all applicable provisions of New York City Building Code, specifically Subchapter 17, and with Reference Standards 17-3, 17-3A, 17-3B, 17-3C and 17-5.
2. Installation shall be in accordance with the manufacturer's recommendation and with UL standard.
3. Underwriters Laboratories Inc.'s listing requirements and limitations shall be complied with.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance December 4, 2006  
Examined By Donald [Signature]