



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 35-07-E

Manufacturer: System Sensor, Unincorporated Div. Of Honeywell Int'l. Inc., 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): System Sensor

Product: Fire alarm equipment

Pertinent Code Section(s): Subchapter 17 and Reference Standard RS-17

Prescribed Test(s): UL 268

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): S911, Project 06NK30126, issued January 17, 2007

Description: Fire alarm equipment.

Model No.	Description
ED-II	Intelligent Ion Detector

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated February 8, 2007, F.P. Index #0702004.

Terms and Conditions: The above unit is accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with the provisions of New York City Building Code, specifically Subchapter 17 and with Reference Standard 17-3, the Electrical Code of the City of New York and applicable Fire Prevention Directives.
2. The installation and spacing of unit shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL standard 268.
3. The above product shall be used only with MEA-approved and compatible control panels and accessories.
4. Periodic maintenance and sensitivity tests shall be conducted in accordance with the regulations of the Fire Department.
5. UL and manufacturer's maintenance procedures and limitations shall be complied with.
6. Unit shall be used in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance February 26, 2007

Examined By

Donald J. [Signature]