



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 352-91-M Vol.2

**Manufacturer:** Elkhart Brass Mfg. Inc., 1302 West Beardsley Avenue, Elkhart, IL 46514

**Trade Name(s):** Elkhart Brass

**Product:** 2.5-inch pressure reducing valves

**Pertinent Code Section(s):** Subchapter 17 and Reference Standard RS 17.

**Prescribed Test(s):** UL 1468 and UL 38.

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** File Ex1164 Project 86NK14377, 95NK30459, 98NK31491 and 05NK20782 issued April 21, 1988, revised December 2, 2005

### **Description:**

A 2.5-inch Pressure Reducing Valve (PRV), for working pressures not exceeding 400 psig, designed for use in fire suppression systems.

### **Model Numbers:**

URFA-20S-2.5: A 2.5-inch in-line valve with female NPT inlet and outlet connections

URFA-20-2.5: A 2.5-inch angle valve with female NPT inlet and outlet connections

URFA-25-2.5: A 2.5-inch angle valve with female NPT inlet and male hose outlet connections

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objection letter dated June 6, 2006, F.P. Index #0605073 & #06-5069A.

**Terms and Conditions:** The above units are accepted on condition that:

1. All uses, applications and installations shall comply with all New York City rules, regulations and codes, specifically New York City Building Code, Subchapter 17. Further, the installation shall be in accordance with Reference Standards 17-2, 17-2A, 17-2B & 17-3 and UL Standards.
2. Installation of all the above models shall be in compliance with Underwriters Laboratories Inc.'s listing requirements and limitations.
3. Installation of all above referenced models shall be in accordance with the manufacturer's recommendations, maintenance procedures and limitations.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance July 15, 2006  
Examined By Donald [Signature]