

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner

**MEA 355-03-E  
Report of Material and Equipment Acceptance Division**

**Manufacturer – Ideal Standard Webco Trane Ind., E. Comercio Av. Dos Pinheirals, 585 Araucaria, Panan, Brazil CEP83.705-570.**

**Trade Name(s) – Trane.**

**Product – Split system air condensing units.**

**Pertinent Code Section(s) - 27-770, 27-777.**

**Prescribed Test(s) – RS 13-6 (ANSI B9.1), RS 13-8 (UL303); UL 1995.**

**Laboratory – Intertek Testing Laboratories.**

**Test Report(s) – No. 3033773-001, dated July 11, 2003.**

**Description – Split system air cooled condensing units, designed for outdoor installation. R-22 is the refrigerant used for the system. Unit consists of hermetic sealed compressor, air cooled condenser with fan and safety controls. Units, with model numbers, nominal cooling capacities, are listed below:**

<b>Model No.</b>	<b>Mfr.'s Specified Nominal Cooling Capacity BTUH</b>
TTK509E5UAO	9,000
TTK512E5UAO	12,000
TTK518E5UAO	18,000
TTK524E5UAO	24,000
TTK530E5UAO	30,000
TTK536E5UAO	36,000

Recommendation - That the above described air cooled condensing units be accepted for outdoor installation, when utilizing refrigerant R-22, under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, Subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 3/15/04

Examined By *[Signature]*