

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

MEA 359-00-E

Report of Material and Equipment Acceptance Division

Manufacturer - Fire Control Instruments, 301 Second Avenue, Waltham, MA 02451.

Trade Name(s) - Fire Control Instruments Inc., System Sensor.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR)

Test(s) - UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - ML File No. S1949, issued September 13, 1991 and revised July 10, 2000.

Description - Multiple Listing of Monitor Module as follows:

System Sensor, Division of Pittway Corp. Basic Applicant's (Supplier's) Product Designation	Fire Control Instruments Inc. Multiple Listee's Product Designation
FSM-101	AMM-2MS

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention had no objections to equivalent model number, letter dated March 23, 2000, F.P. Index No. 9912073A (under MEA 457-99-E).

Recommendation - That the above units be accepted on conditions that all uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17 and with the Reference Standard RS 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, the UL Listing and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance October 5, 2000

Examined Mark J. Kelly