



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 365-05-E

Manufacturer: FPI Fireplace Products International Ltd., 6988
Venture Street, Delta, BC V4G 1H4, Canada

Trade Name(s): Regency

Product: Direct-vent gas insert

Pertinent Code Section(s): RS14-6 (ANSI Z21.88b-2003)

Prescribed Test(s): Venting Gas Fireplace Heaters

Laboratory: Intertek Testing Services NA Ltd.

Test Report(s): ITL #476-3078954-1/05, dated July 18, 2005

Description: Direct-vent gas insert, Model No. E33.

Terms and Conditions: The above-described vented gas-fired appliances are accepted for decorative heating operation under the following conditions:

1. Natural gas shall be used for indoor installation only, with combustion air and required ventilation air provided.
2. Venting of the above equipment is subject to Section 27-879 of the New York City Building Code.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.

4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance 11/22/06

Examined by Shyam M. Prasad