



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 371-05-E

Manufacturer: Aerosys, Inc., 32 Thomas Jefferson Drive, Frederic, MD 21702

Trade Name(s): Ceilmate

Product: Ceiling-mounted air conditioner units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11 (UL 1995)

Laboratory: Met Laboratories, Inc.

Test Report(s): No. 16636, File 112295, dated October 18, 2005

Description: Computer room air conditioners as listed below:

Model No.	Mfr.'s Specified Nominal Cooling, Tons
CM 12	1.00
CM 18	1.50
CM 24	2.00
CM 30	2.5
CM 36	3.0

Note: Model number may have variable prefix and/or suffix digits.

Terms and Conditions: The above air conditioning is accepted under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.
3. Approval of electric equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 12/14/06

Examined by Shyam-Prasad