



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 38-07-E

Manufacturer: ARNEG LLC, 4243 Lonat Drive, Nazareth, PA 18064

Trade Name(s): ARNEG LLC

Product: Commercial refrigerators and freezers, remote systems

Pertinent Code Section(s): 27-771, 27-772

Prescribed Test(s): RS 14-6 (UL 471)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File SA8240, Vol. 1, Sections 1, 2, 3,6,7,9,10,12,13, 16 and 20 dated August 8, 1989, revised September 2, 1994

Description: Commercial refrigerators and freezers for use with remote condensing units in food stores. Units are comprised of on/off switches, remote condensing units, interconnecting refrigerant lines, expansion valves, refrigeration controllers and evaporators.

Product Covered

Remote Models: AD-1250, -1875, -2500, -3750; BILBAO-8, -12; BL-1875, -2500, -3750; BN-180, -240, -360; BR-1562, -2343, -3124, -3898; CH-2440, -3660; EV-900R, -1200R, -1800R; FR-1250R, -1875R, -2500R, -3672; GZ-900R, -1200R, -1800R; KY-937R, -1250R, -1875R, -2500R, -3125R; LACOLLE-6, -8, -10, -12; LE-900, -1800; LV-1200R, -1800R, -2400R; LZ-1200, -1200S, -1800, -1800S, -2400, -2400S; MALMOE-8, -12, -HEAD; MINIMALMOE; MD-2500, -3750; ML-2500, -3750; MN-900R, -1200R, -1800R; NM-180, -240, -360; NP-120, -240, -360; Ottawa-6, -8, -12; PHI680R, PHIJ1460R, -1460RSS, -1918R, -1918RSS; PHOENIX-3R, -4R, -5R, -6R, -8R; RTB-1350, -1975, -2600; SE-2400, -3600; SMD-2500, -3750; Sofia SO-937R, -1875R; SP-2400R, -3600R; SUPER BILBAO-8, -12; SV-1200R, -1200RS, -1500R, -1500RS, -1800R, -1800RS, -2400R, -2400RS, -3000R, -3000RS; SVF-4, -6, -8, -12; TL-1250R, -1250RC, -1250RS, -1875R, -1875RC, -1875RS, -2500R, -2500RC, -2500RS, -3750R, -3750RC, -3750RS;

TL-A.AP, -A.CH; TR-900R, -1200R, -1800R; TPV-4, -6, -8, -12; YK-1250R, -1250C, -1250RS, -1875R, -1875RC, -1875RS, -2500R, -2500RC, -2500RS, -3750R, -3750RC, -3750RS; YK-A.AP, -A.CH; YKS-1875RP, -1875RS, -2500RP, -2500RS,

Models: FL01-1, FL01.2; FL01B-1, FL01B-2; FL01BTE; PL05-1, PL05-2, PL05-3, PL05E BRUXELLE, CHAMPAGNE, ROLL-IN, PV03-1, PV03-2, PV03-3, PV03-4, PV03-5 PV01, PV01S; SLS, SVFO; TPV01, TPV02; VF04, VF06.

Terms and Conditions: The above-described commercial refrigerators and freezers are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Building and Electrical Code requirements.
2. Adequate supply of fresh air shall be provided for ventilation into room or space enclosing equipment.
3. The installation shall not obstruct access for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 4/25/07

Examined By 