



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 382-94-E Vol. 7

**Manufacturer:** Signal Communications Corporation

**Trade Name(s):** SigCom

**Product:** Manual Station Protective Covers; Manual Station.

**Pertinent Code Section(s):** Reference Standard 17, Subchapter 17.

**Prescribed Test(s):** UL 38

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File S5654, Project 94NK23007, dated October 21, 1994, revised April 21, 2004. UL File S5654, Project 01NK4936, issued April 5, 2001.

**Description** – Sentry Manual Fire Alarm Station Covers, Model ST-FRC01 with the following options: ST-BKP01 – Backplate Kit; ST-XTR01 – Extender Kit; ST-WPK01 – Weatherproof Kit; ST-ALM01 – Alarm Module Kit; SG-32CX – Manual Pull Station.

Pursuant to “Promulgation of the Rules relating to Materials and Equipment Application Procedures” dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated October 4, 2005, FP Index No. 0509013A.

**Terms and Conditions:** That the above units be accepted on condition that all uses, configurations, arrangements and functions, application and installations shall comply with all applicable provisions of New York City Buildings Code, specifically Subchapter 17 and Reference Standards 17-3. Further, the installation and use shall be in accordance with manufacturer’s recommendations, NFPA 72 and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 18, 2006.

Examined by Donald [Signature]