

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner  
MEA 383-02-E

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name(s) – Notifier.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) –RS 17-3, RS 4-6 (886-89-BCR).

Test(s) – UL 521.

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – UL File S2101, Volume 2, Section 2, issued June 1, 1999, revised October 10, 2002.

Description – Models FST 851 and FST 851H are electronic fixed temperature heat detectors and Model FST851H is an electronic rate of rise w/fixed temperature heat detector.

Model Number	Description
FST851	Heat Detector (135°F Rating)
FST851R	Heat Detector (135°F Rating)
FST851H	Heat Detector (190°F Rating)

Pursuant to “Promulgation of the Rules relating to Material and Equipment Application Procedures” dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated November 15, 2002, F.P. Index 0211007.

Recommendation - That the above equipment be accepted on condition that all uses, configurations, arrangements and functions, applications, and installations shall comply with the provisions of New York City Buildings Code, Subchapter 17, and Reference Standard RS-17-3. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance FEBRUARY 11, 2003

Examined by 