



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 384-02-E Vol.4

Manufacturer: System Sensor, Unicorporated Division Of Honeywell International Inc. 3825 Ohio Avenue, St. Charles, Illinois 60174

Trade Name(s): Silent Knight

Product: Fire Alarm Equipment

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89-BCR)

Prescribed Test(s): UL 268A

Laboratory: Underwriters Laboratories

Test Report(s): Multiple Listings File No. S6173 Issued 7-21-05 Revised 5-04-06.

Description – The units are intended to detect an abnormal amount of smoke density in return air ducts of air conditioning and ventilating systems. The units operate to shut down blowers to prevent abnormal smoke distribution and a possible panic hazard. The duct detectors consist of a plastic enclosure, relay, electrical components, listed open area detector, and a sampling and exhaust tube.

Silent Knight Model Number	Notifier Model Number	Description
IDP-PDUCT	FSD-751 PL	Smoke-automatic fire detector
IDP-PDUCT-R	FSD-751 RPL	Smoke-automatic fire detector

Terms and Conditions: That the above equipment be accepted provided that all uses, locations, and installations shall comply with Subchapter, Reference Standard RS-17 of the New York City Building Code, the Electrical Code of the City of New York, applicable Fire Prevention Directives, and the manufacturer's instructions.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance July 10, 2006
Examined By Donald [Signature]

