



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 385-07-E

Manufacturer: System Sensor, Unicorp. Div. of Honeywell Int'l., 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): System Sensor

Product: Fire alarm equipment

Pertinent Code Section(s): Subchapter 17 and Reference Standard RS 17

Prescribed Test(s): §27-969 (UL 268)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): S911, Volume 125, Section 2, Project 07NK15514 issued October 23, 2007

Description: Fire alarm equipment.

Model No.	Description
2112i3	Automatic smoke detector

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated November 5, 2007, F. P. Index #0711033.

Terms and Conditions: The above units are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installation shall comply with the provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard RS 17. Further, the installation and spacing of detectors shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL 268.
2. The above product shall be used only with approved and compatible control panels and accessories.
3. Periodic maintenance and sensitivity tests shall be conducted in accordance with the regulations of Fire Department.
4. UL and manufacturer's maintenance procedures and limitations shall be complied with.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance November 29, 2007.
Examined By Donald J. [Signature]