

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner
MEA 389-00-E

Report of Material and Equipment Acceptance Division
Manufacturer - System Sensor, A Division of Pittway, 3825 Ohio Avenue,
St. Charles, IL. 60174

Trade Name(s) – Notifier.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 268A.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S911, Project 99NK38889, issued March 24, 2000 and revised August 24, 2000 and UL letter dated October 4, 2000.

Description – Notifier's Smoke-Automatic fire detector as follows:

Model No.	Description
FSD-751RP	Smoke-Automatic Fire Detector for duct applications where the velocity is between 600 and 4000 ft./min.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated October 18, 2000, F.P. Index No. 0010023.

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements, functions, locations and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-11 and 17-12. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, the UL listing and the UL standard. Model FSD-751RP duct detector shall be used with listed and approved control panels with which the compatibility has been determined by a UL test report.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance October 30, 2000

Examined By Mark J. Kelly