



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 390-02-E Vol. 7

Manufacturer: System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): Notifier

Product: Fire Alarm Equipment

Pertinent Code Section(s): RS 17-3, Subchapter 17

Prescribed Test(s): UL 521

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): Multiple Listing, File No. S747 issued April 12, 1993 and revised April 9, 2008.

Description: Heat detectors.

Notifier Model No.	System Sensor Model No.	Description
NH – 100H	5251H	Heat Detectors

Terms and Conditions: The above heat detectors are accepted provided that:

1. All uses, locations, and installations comply with Article 17, Reference Standard RS 17 of the New York City Building Code, the Electrical Code of the City of New York, applicable Fire Prevention Directives and the manufacturer’s instructions.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance May 12, 2008

Examined By Donald [Signature]