

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

MEA 397-00-E

Report of Material and Equipment Acceptance Division

Manufacturer - Systems Sensor, A Division of Honeywell International, 3825 Ohio Avenue, St. Charles, IL. 60174

Trade Name(s) - System Sensor.

Product - Fire Notification Appliances.

Pertinent Code Sections - 27-968 through 27-977, RS 17-5 ANSI/NFPA No. 72.

Test(s) - UL 464.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S4011, Project 00NK22935, Volume 1, Section 3, issued September 6, 2000, and UL letter dated October 23, 2000.

Description - System Sensor's Chime/Sounders as follows:

Model No.	Description
CH12/24	Chime/Sounder, red 8-33 Volts
CH12/24W	Chime/Sounder, white 8-33 Volts

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated December 1, 2000, F.P. Index No. 0011007.

Recommendation - That the above units be accepted on condition that all uses, locations and installations comply with the New York City Building Code, specifically Subchapter 17, Reference Standards RS 17-3, inclusive as applicable including the NFPA as appropriate, the UL listing, manufacturer's instructions, the Fire Department Directives, and with the Electrical Code of the City of New York and on further condition that:

The provisions RS 17-3 requires that all sounding devices using Chime tone be installed only under special approval granted by the Commissioner for each site. This installation is for a private mode signaling only.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance January 5, 2001

Examined Mark J. Kelly