



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 397-07-M

Manufacturers:

Dansk Eternit Holding A/S
Hasserisvej 139
P.O. Box 750
DK-9100 Aalborg
Denmark

&

American Fiber Cement Corp.
6901 S. Pierce Street, Suite 260
Littleton, CO 80128

Trade Name(s):

Minerit HD

Product:

Un-pigmented fibers cement board

Pertinent Code Section(s):

27-335-1

Prescribed Test(s):

RS 5-5 (ASTM E136), Toxicity

Laboratory:

SGS U.S. Testing Company, Inc. (SGS)
Anderson Laboratories, Inc. (AL)

Test Report(s):

SGS Test #177:007388
AL Test #670, Sample #V-441-1, dated
December 20, 2007.

Description: Minerit HD is a moisture-resistant, un-pigmented, fiber-reinforced cement board for exterior cladding. Minerit HD has a high-resistance to extreme weather conditions and corrosion. Minerit HD panel has 3.2mm to 12mm thickness, is paintable and retains the ASTM E136 and toxicity rating per building code requirements.

Terms and Conditions: The above-described fiber cement board is accepted for exterior cladding usage with the following conditions:

1. Fiber cement board is to be hung in accordance with the New York City Building Code.
2. All safety precautions must be adhered to when hanging fiber cement board in accordance with OSHA standards or Building Department standards, whichever provides the highest degree of safe handling.
3. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials are equivalent to those tested and accepted for use, as provided for in Article 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance January 23, 2008
Examined By Sion Derkshidam