

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

**MEA 398-00-E
Report of Material and Equipment Acceptance Division**

Manufacturer - Systems Sensor, A Division of Pittway, 3825 Ohio Avenue, St. Charles, IL. 60174

Trade Name(s) - Honeywell.

Product - Fire Alarm Equipment.

Pertinent Code Sections - RS 17-3, RS 4-6 (886-89-BCR).

Test(s) - UL 268.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S911, Project 99NK37501, Volume 51, Section 1, issued January 12, 2000, revised August 3, 2000 and UL letter dated October 25, 2000.

Description - Honeywell's smoke detector as follows:

Model No.	Description
TC840M1005	Photoelectric with Heat Smoke Detector

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated December 1, 2000, F.P. Index No. 0011003.

Recommendation - That the above photoelectric smoke detector be accepted on condition that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of the New York City Building Code, specifically Subchapter 17, Reference Standards RS 17-3 and the UL listing. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72 and the UL standard. The referenced detector shall be used only with approved base assembly with which the compatibility has been determined by a UL test report.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance March 23, 2001
Examined Mark Jachy