



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 40-07-E

**Manufacturer:** ARNEG LLC, 4243 Lonat Drive, Nazareth, PA 18064

**Trade Name(s):** ARNEG LLC

**Product:** Self-contained refrigerators and freezers

**Pertinent Code Section(s):** 27-771, 27-772

**Prescribed Test(s):** RS 14-6 (UL 471)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** File SA8240, Vol. 1, Sections 1, 2, 3,6,7,9,10,12,13, 16 and 20 August 7, 1989, revised August 10, 1995

**Description:** Self-contained commercial refrigerators and freezers, as listed below. These units are reach-in and pass-through types for use in food service establishments. Units are comprised of on/off switches, condensing units, outlet boxes and junction boxes, refrigerant dryers, evaporators and evaporator fans. Condensing units are equipped with compressors, starting capacitors, condensers, condenser fans, interior lighting, fan motors and receivers. Evaporators are thermostatically-controlled. Freezer models have defrosted heaters and defrost timers. Type of refrigerant used is R12, R22 or R502.

#### Self-contained Models:

BN-1800, -2400; EV-900, -1200, -1800; FR-1250, -1875, -2500R;  
GZ-900R, -1200R, 1800R; IB-1000, -1000SS, -1340, -1340SS, -1680, -1680SS;  
KY-937, -1250, -2500, -3125; LE-900, -1800; LV-1200, -1800, 2400;  
LZ-1200R, -1200RS, -1800R, -1800RS, -2400R, -2400RS;  
ML-2500, -3750; MN-900, -1200, -1800; PHI680, PHII1460, -1460SS, -1918, -1918SS;  
PHOENIX-3, -4, -5, -6, -8; PV05-4, -6, -8, -12; SA-1320, -1920; Sofia SO-937, -1875;  
SV-1200, -1200S, -1800, -1800S, -2400, -2400S, -3000, -3000S;  
TO-1000, -1320; TR-900, -1200, -1800; YK-1250, -1250C, -1250S, -1875, -1875C, -1875S,  
-2500, -2500C, -2500S, -3750, -3750C, -3750S; Small Cart, Large Cart.

**Terms and Conditions:** The above-described commercial refrigerators and freezers are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Building and Electrical Code requirements.
2. Adequate supply of fresh air shall be provided for ventilation into room or space enclosing equipment.
3. The installation shall not obstruct access for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 4/25/07

Examined By Stacy M. [Signature]