



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 407-06-E Vol. 2

Manufacturer:	System Sensor, Unicorp. Div. Of Honeywell Int'l. Inc., 3825 Ohio Avenue, St. Charles, IL 60174
Trade Name(s):	System Sensor
Product:	Battery-operated, smoke-automatic fire detector and RF transmitter for open-area protection
Pertinent Code Section(s):	Subchapter 17 and Reference Standard RS 17
Prescribed Test(s):	UL 268
Laboratory:	Underwriters Laboratories, Inc.
Test Report(s):	UL File S911, Project 05NK03788, issued May 26, 2006, revised September 21, 2006

Description – Battery-operated, smoke-automatic fire detectors, Model W3-ADT, will operate to produce a smoke alarm when sufficient smoke is present in the detector chamber.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated November 20, 2006, F.P. #0611019.

Terms and Conditions: The above equipment is accepted provided that:

1. All uses, configurations, arrangements and functions, application and installations comply with applicable provisions of the New York City Building Code, specifically Subchapter 17, and with Reference Standard 17-3.
2. The installation, use and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 (2002 edition, section 6.16) and UL standard.
3. Periodic maintenance and sensitivity tests shall be conducted in accordance with the requirements of 3RCNY§17-06. Signal strength shall be tested at least weekly and record of such testing shall be kept on the premises for inspection.
4. The product shall be used only with MEA-approved compatible fire alarm panels, devices and accessories.
5. Underwriters Laboratories, Inc.'s listing requirements and limitations shall be complied with.
6. Final installation and use shall be subject to Fire Department inspection and approval.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance December 11, 2006

Examined By Donald [Signature]