



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 407-06-E Vol. 3

Manufacturer: System Sensor, Unincorp. Div. of Honeywell Int'l. Inc., 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): System Sensor

Product: Fire alarm equipment

Pertinent Code Section(s): Subchapter 17 and Reference Standard RS 17

Prescribed Test(s): UL 268

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): S911, Project 05NK03788 issued May 26, 2006, revised February 15, 2007

Description: Smoke detector, Model No. 5806W3.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated April 5, 2007, F.P. Index #0703022.

Terms and Conditions: The above fire alarm unit is accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations shall comply with the provision of New York City Building Code, specifically Subchapter 17 and Reference Standard 17-3. Further, the installation, use and

spacing shall be in accordance with the manufacturer's recommendation, NFPA-72 (2002 edition, Section 6.16) and UL standard.

2. Periodic maintenance and sensitivity tests shall be conducted in accordance with the requirements of 3RCNY§17-06. Signal strength shall be tested at least weekly and record of such testing shall be kept on the premises for inspection.
3. The above-referenced product shall be used only with MEA-approved compatible fire alarm panels, devices and accessories.
4. Underwriters Laboratories, Inc.'s listing requirements and limitations shall be complied with.
5. Final installation and use shall be subject to Fire Department inspection and approval.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of New York City Building Code.

Final Acceptance April 27, 2007
Examined By Donald [Signature]