

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner
MEA 410-00-E

Report of Material and Equipment Acceptance Division

Manufacturer - International Comfort Product Corporation, USA, 650 Heil Quaker Avenue, Lewisburg, Tennessee 37091.

Trade Name(s) - Heil, Tempstar, Airquest, Kenmore.

Product - Gas fired forced air furnaces.

Pertinent Code Section(s) -27-800, 27-825, RS 14-2(ANSI Z223.1).

Prescribed Test(s) - RS 14-6 (ANSI Z21.47).

Laboratory - CSA International.

Test Report(s) - CSA 157229-1028208 dated June 11, 2000.

Description - Upflow/horizontal right or left induced draft gas fired furnaces, Model NTV, designed for indoor installation. Unit consists of variable motor, aluminized steel main burner, heat exchanger assembly, hot surface ignition system comprising pilot burner and igniter (electrode), flame sensor, ignition module and combination gas pressure regulator. Units are provided with a temperature limit control, and flame rollout switch. Units with model numbers and nominal heating capacities are listed below.

Model No.	Mfr.'s. Specified Nominal Heating Capacity BTUH
NTV6050FB	50,000
NTV6075GF	75,000
NTV6100KJ	100,000
NTV6125KJ	125,000

Note: Unit may be installed on combustible flooring. Minimum installed clearances from combustible construction shall be as follows: top-1 inch; front- 6 inches (3 inches with B-1 vent); back- 0 inches; left and right sides- 0 inches; flue connector- 6 inches with single wall vent pipe; 1 inches with Type B-1 vent; 5 inches with thermoplastic pipe.

Recommendation - That the above described air furnaces be accepted for indoor installation with minimum clearances given above, when using natural gas only, under the following conditions:

1. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without closable shutters and duct leading thereto shall be without a damper or, (b) dampers and shutters within the system shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.
2. If furnace is installed in combination with a cooling system, then cooling system must be MEA accepted.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance DEC 29 2000

Examined By S. Derphudam