

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 42-00-M

Report of Material and Equipment Acceptance Division

Manufacturer - Brymor, Tonbridge Road, East Peckham, Tonbridge, Kent England
TN125JX.

Trade Name - Meteor Type 1.

Product - Wallcovering material.

Pertinent Code Section(s) -27-348.

Prescribed Test(s) - RS 5-5 (ASTM E84); Toxicity.

Laboratory - SGS U.S. Testing Company Inc; Anderson Laboratories Inc.

Test Report(s) - 132416-3 dated November 18, 1999 and Anderson No. 499 dated
December 2, 1999.

Description - Type I non-woven backed wall covering material with
polyester/cellulose blend for backing is intended for use as interior finish.
The nominal weight of the material is as follows:

App. 1.8 oz./sq.² backing weight
App. 8.2 oz./sq.² vinyl weight
App. 10.0 oz./sq.² total weight

Flame Spread Rating	15
Smoke Density Rating	55

Recommendation - That the above described wallcovering material be accepted as having interior finish Class A, with flame spread rating as indicated above. Material with a greater smoke density of 25 shall not be used in exits or corridors. Material with greater smoke density of 50 shall not be used in Occupancy H-1 and H-2. Upon exposure to fire the material did not produce products of decomposition or combustion that were more toxic than those given off by wood or paper when decomposing or burning under comparable conditions. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance MAR 31 2000

Examined By S Derkhdam