

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

**Patricia J. Lancaster, F.A.I.A., Commissioner**

**MEA 42-05-M  
Report of Material and Equipment Acceptance Division**

**Manufacturer- The Gage Corporation, Int., 803 S. Black River Street, Sparta Wisconsin 54656.**

**Trade Name- Gage Metal.**

**Product- Decorative metal ceiling and wall panel for interior finish acceptance.**

**Pertinent Code Section(s)- 27-348.**

**Prescribed Test(s)- Noncombustibility (27-232).**

**Test Report- Actual sample aluminum panel on file.**

**Description- Decorative aluminum ceiling panel and metal wall surfacing for interior finish is made of all aluminum metal. The panels are all manufactured in different designs and colors.**

**Recommendation – That the above described aluminum ceiling tile and metal wall surfacing be accepted for interior finish usage, with Class A as indicated above. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.**

**Final Acceptance** May 12/05  
**Examined By** S. Derk Hudson