

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

MEA 428-00-E

Report of Material and Equipment Acceptance Division

Manufacturer – Valor Heating, Bermington, England, P.O. Box 604, Portland, TN 37148.

Trade Name – Valor.

Product – Gas fired vented decorative fireplace heater.

Pertinent Code Section(s) – 27-800, RS 14-2 (ANSI Z223).

Prescribed Test(s) - RS 14-6 (ANSI Z21.88-1998).

Laboratory – CSA International.

Test Report(s) – Certification No. 189576-1112373, dated July 21, 2000.

Description – Gas fired decorative fireplace insert designed to provide supplemental heating and to enhance the aesthetics of a room. Both units are fan forced heat circulating and similar in function and differ only in size.

Products	Type	Max. Input Rating BTUH
535AN	Gravity	30,000
534AN	Gravity	24,000

Recommendation - That the above described gas-fired vented appliances, be accepted for decorative heating operation on natural gas only, for indoor installation only with combustible air and required ventilation air provided. Venting of the above equipment is subject to Section 27-879 of the Building Code. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 12/25/2000

Examined By Satish K. Babbar