

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner

MEA 436-00-E

Report of Material and Equipment Acceptance Division

Manufacturer– Cookshack Inc., 2304 N. Ash Street, Porka City, OK 74601.

Trade Name(s) – Cookshack Smoker oven.

Product – Electric smoker oven.

Pertinent Code Section(s) - 27-777(d), 27-787, 27-792.

Prescribed Test(s) -RS 14-6 (UL197).

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – UL E91026, dated July 9, 1985 , revised December 3, 1999; May 29, 1984, revised September 15, 2000.

Description – Electric smoker oven/dehydrator used for cooking traditional pit style barbecue, smoke food and dried foods. The units are on caster, so they can be moved to various locations to cook. Units produce small amounts of smoke, which needs to be vented out of the cooking area. Unit comprises heating elements, thermostat and cooling fans.

Product Covered:

Electrical Ratings:

Model	V, 60 Hz	W	Phase
150, 160, DH101, DH102	110	1550	1
075, 076	120	1250	1
250, 260	120/240	3050	1
350, 360	208	6000	1

Note: Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Recommendation - That the above electric ovens be accepted, under the following conditions:

- 1. Unit shall be installed in accordance with manufacturer's instructions, and the New York City Electrical, Building and Fire Codes requirements.**
- 2. Cooking equipment shall be installed under hoods that vent to the outside and comply with Reference Standard RS-13 requirements of the New York City Building Code and have a fire suppression system complying with Reference Standards RS 13-2 and RS 13-3 with open heads and capable of simultaneous discharge and manual release. The Fire Suppression System exclusively used for cooking equipment shall be filed with the Building Department and examined and approved by the Fire Department.**
- 3. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.**
- 4. The installation shall not interfere with accessibility for operation and serving.**
- 5. For grease removal, suitable baffle type grease filters, MEA accepted, shall be installed.**
- 6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.**
- 7. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.**

Final Acceptance 1/22/01
Examined by Stephen M. Ince