



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 442-06-E

Manufacturer: Fire Lite Alarms, One Fire-Lite Place, Northford, CT 06472-1653

Trade Name(s): Fire-Lite Alarms

Product: Fire alarm equipment

Pertinent Code Section(s): 27-968 through 27-981, Reference Standard RS 17

Prescribed Test(s): UL 864

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File S624, Project 05ME14053, issued May 10, 2006
UL File S2424, Project 05ME14053, issued May 10, 2006
UL Multiple Listing, File S2424, issued June 6, 2006

Description: The Ms-9050UD is a 50 point addressable fire alarm control panel with on board digital alarm communicator transmitter (DACT). The ANN-80 is an 80 character LCD annunciator, the ANN-I/O is graphic annunciator driver and the ANN-S/PG is a printer module.

Silent Knight Model	Model	Description
	MS-9050UD	Fire Alarm Control Panel
	ANN-80	Remote Annunciator
5880	ANN-I/O	Option Module – Graphic Annunciator
5824	ANN-S/PG	Option Module – Printer

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objection letter dated August 11, 2006, F.P. Index #0607067.

Terms and Conditions: The above units are accepted on condition that:

1. All uses, configurations, arrangements, functions, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and with Reference Standards RS 17-3 through 17-3C, NFPA 72, UL 864 Standard, the manufacturer's instructions, the Fire Department Rules and the New York City Electrical Code.
2. When used with central office communicator or a transmitter, the installation and operation of these control units and devices shall comply with 3RCNY §17-01. It shall have the capability of transmitting separate and distinct signals to indicate manual pull station alarm, automatic detection alarm, sprinkler waterflow alarm, supervisory signal indications and trouble indications.
3. The connection of security/burglar devices and equipment to the fire alarm control unit is prohibited. A sign must be provided to indicate same.
4. Installation of pre-recorded evacuation messages in the fire alarm control unit shall have prior approval from the Department of Buildings.
5. Remote annunciator, model ANN-80, is acceptable under the condition that all controls of fire alarm shall be removed from these units except the alarm-acknowledge function.
6. All above-referenced fire alarm equipment shall be painted red in color.
7. The above-referenced fire alarm control units shall be used only with listed, approved or accepted equipment and accessories with which the compatibility has been determined by the Engineer of Record or a UL test report.
8. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance October 23, 2006
Examined By Donald [Signature]