



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 442-06-E Vol.2

Manufacturer: Honeywell International, 12 Clintonville Road
 Northford, CT 06472-1653

Trade Name(s): Notifier/ADT Security Services, Inc.

Product: Fire alarm equipment

Pertinent Code Section(s): 27-968 thru 27-981, Reference Standard RS 17

Prescribed Test(s): UL 864

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL multiple listing files S635 issued October 12, 1987. Revised May 23, 2006, S635 issued May 17, 2006, S635 issued August 7, 2006, S232 issued July 24, 2006.

Description: Notifier's fire warden 50 fire alarm control unit is multiple listed with Fire-Lite Alarms, Inc. MS-9050UD. Notifier's N-ANN-80 and ADT Security Services, Inc. ADT-ANN-80 Remote Annunciators are multiple listed with Fire-Lite Alarms, Inc. ANN-80; Notifier's N-ANN-S/PG Option Module-Printer; and N-ANN-I/O Option Module-Graphic Annunciator is multiple listed with Silent Knight's 5824 and 5880 respectively.

Notifier	ADT Security	Silent Knight Model	Fire-Lite Model	Description
Fire Warden-50			MS-9050UD	Fire Alarm Control Panel
N-ANN-80	ADT-ANN-80		ANN-80	Remote Annunciator
N-ANN-S/PG		5824	ANN-I/O	Option Module - Graphic Annunciator
N-ANN-I/O		5880	ANN-S/PG	Option Module - Printer

Terms and Conditions: The above units are accepted on condition that:

1. All uses, configurations, arrangements, functions, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and with Reference Standards RS 17-3 through 17-3C, NFPA 72, UL 864 Standard, the manufacturers' instructions, the Fire Department Rules and the New York City Electrical Code.
2. When used with central office communicator or a transmitter, the installation and operation of these control units and devices shall comply with 3RCNY §17-01. It shall have the capability of transmitting separate and distinct signals to indicate manual pull station alarm, automatic detection alarm, sprinkler waterflow alarm, supervisory signal indications and trouble indications.
3. The connection of security/burglar devices and equipment to the fire alarm control unit is prohibited. A sign must be provided to indicate same.
4. Installation of pre-recorded evacuation messages in the fire alarm control unit shall have prior approval from the Department of Buildings.
5. Remote annunciator's models ANN-80, N-ANN-80 and ADT-ANN-80 are acceptable under the condition that all controls of fire alarm shall be removed from these units except the alarm-acknowledge function.
6. All above referenced fire alarm equipment shall be painted red in color.
7. The above-referenced fire alarm control units shall be used only with listed, approved or accepted equipment and accessories with which the compatibility has been determined by the Engineer of Record or a UL test report.
8. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance June 1, 2007.

Examined by

Donald J. [Signature]

