



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 442-06-E Vol. 3

Manufacturer: Fire-Lite Alarms, One Fire-Lite Place, Northford, CT 06472

Trade Name(s): ADT Security Services Inc.

Product: Fire alarm equipment

Pertinent Code Section(s): 27-968 through 27-981, Reference Standard RS 17

Prescribed Test(s): UL 864

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL Multiple Listing File No. S232, issued May 28, 1992 and revised July 24, 2006.

Description: The Unimode-9050UD is a 50-point addressable fire alarm control panel with on-board digital alarm communicator transmitter (DACT).

ADT Security Model No.	Fire-Lite Model No.	Description
Unimode-9050UD	MS-9050UD	Fire Alarm Control Panel

Terms and Conditions: The above units are accepted on condition that:

1. All uses, configurations, arrangements, functions, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and with Reference Standards RS 17-3 through 17-3C, NFPA 72, UL 864 Standard, the manufacturer's instructions, the Fire Department Rules and the New York City Electrical Code.
2. When used with central office communicator or a transmitter, the installation and operation of these control units and devices shall comply with 3RCNY §17-01. It shall have the capability of transmitting separate and distinct signals to indicate manual pull station alarm, automatic detection alarm, sprinkler waterflow alarm, supervisory signal indications and trouble indications.
3. The connection of security/burglar devices and equipment to the fire alarm control unit is prohibited. A sign must be provided to indicate same.
4. Installation of pre-recorded evacuation messages in the fire alarm control unit shall have prior approval from the Department of Buildings.
5. All above-referenced fire alarm equipment shall be painted red in color.
6. The above-referenced fire alarm control units shall be used only with listed, approved or accepted equipment and accessories with which the compatibility has been determined by the Engineer of Record or a UL test report.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance July 10, 2007
Examined By Donald [Signature]