



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 445-06-E

Manufacturer: DESA Heating LLC, 2701 Industrial Drive, Bowling Green, KY 42101

Trade Name(s): Master Heater

Product: Convection heater and forced-air heater

Pertinent Code Section(s): 27-800, 27-826

Prescribed Test(s): RS14-6, RS15-2 (ANSI Z83.7), RS 15-2

Laboratory: CSA International

Test Report(s): 1352538, dated 6/9/06

Description: Natural gas-fired convection and forced-air construction heater to be used as temporary heat in buildings or structures under construction, alteration or repair.

Product Covered: Convection heater – TC100
Forced-air heater – BNG 150T

Terms and Conditions: The heaters described above are accepted subject to the following conditions:

1. Heater must operate on natural gas only.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
3. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 10/12/06

Examined by Shyam S. Sengupta