



NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### **MEA 446-04-M`**

**Manufacturer:** LAMBR INTERNATIONAL, OOST Knaaldijk 6, Maarsse, Holland 3603CZ

**Trade Name(s):** WOODTRENDS

**Product:** WOOD VENEERED PANEL FOR INTERIOR FINISH ACCEPTANCE

**Pertinent Code Section(s):** 27-348

**Prescribed Test(s):** RS 5-5 (ASTM E 84) TOXICITY

**Laboratory:** V TEC LABORTORIES, ANDERSON LABORATORIES INC.

**Test Report(s):** VTEC #100-1451-1 DATED NOVEMBER 19 2005 AND AL TEST # 628 DATED AUGUST 2, 2005

**Description** – Wood Veneered to a fire retardant treated medium density fiber board. Panels are either Slotted or perforated to produce acoustical qualities. Panels are finished with UV-Polyacrylate lacquer. Panels are used to adjust the acoustics of an area by either applying the panels to the ceiling or wall or a combination of both. Flame Spread rating-25 and Smoke Developed Index-30

**Terms and Conditions:** That the above described Wood Veneered panel material is accepted for interior finish usage, with Class A flame spread rating and smoke developed rating as indicated above. Upon exposure to fire the material did not produce products of decomposition or combustion that were more toxic than those given off by wood or paper when decomposing or burning under comparable conditions. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 21-131 of the Building Code.

Final Acceptance June 22, 2006

Examined by Sjur Derkshidan