



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 453-06-M

Manufacturer: Chikako Hanaoka, 350 Fifth Avenue, Suite 7500, New York, N.Y. 10018

Trade Name(s): Astratta

Product: Wall covering product

Pertinent Code Section(s): 27-348

Prescribed Test(s): RS 5-5 (ASTM E-84); Toxicity

Laboratory: Intertek Testing Services; Anderson Laboratory

Test Report(s): Intertek Testing Service Report, Project #49802-3080926-500, dated July 29, 2005; Anderson Laboratory test report, #635 sample #v-411, dated January 8, 2006

Description: Astratta is 16.8 oz/lin. yd. @ 36½” wide, intended for use as interior-finish, specifically wall covering. The following style is included

Face – 100% caustic soda lime beads
Backing – 100% paper

Astratta #5666: Flame Spread Rating – 25
Smoke Development Rating – 15

Terms and Conditions: The above-described wall covering material, having interior-finish usage with Class A Flame spread rating and smoke developed rating as indicated above, is accepted provided that:

1. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance _____

Examined By Sum D. K. Redar