



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 455-06-E

Manufacturer: System Sensor, Unincorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, ILL 60174

Trade Name(s): System Sensor

Product: Fire alarm equipment

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89-BCR)

Prescribed Test(s): UL 753 and UL 346

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File S739 issued April 1, 1993, revised March 10, 2006.

Description: Model No. EPS10-2V – Pressure Switch

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated August 30, 2006, F.P. Index #0608020.

Terms and Conditions: The above unit is accepted on condition that:

1. All uses, applications and installations comply with all applicable provisions of New York City Building Code, specifically Subchapter 17 and Reference Standards 17-2, 17-2A, 17-2B and 17-3.
2. The installation shall be in accordance with the manufacturer's recommendation and UL Standard.
3. Manufacturer's maintenance procedures and UL listing requirements & limitations shall be complied with.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance September 25, 2006
Examined By Donald [Signature]