



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 456-06-E

**Manufacturer:** Ingersoll-Rand, Security Technologies, 3899 Hancock Expressway, Security, CO 80920

**Trade Name(s):** Schlage L-Lock

**Product:** Electrically controlled single-point locks or latches

**Pertinent Code Section(s):** 27-371 (j) of New York City Building Code, Reference Standard RS 17-3, -3A and -3B

**Prescribed Test(s):** UL 10B and UL 10C

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** File R8458, Project 06NK05492, issued February 20, 2006.

**Description:** Electrified Locking (Fail/Safe) – unlocked by switch or power failure.

Model No.	Description
LV9080EL	Electrically locked single point lock or latch set for mortise type. The lock can potentially be connected to electrically-controlled systems in commercial buildings. The outside lever continually locks electrically and unlocks by key from outside, or by switch or power failure. In addition, vandal-guard is designed to disengage outside spindle from latch when in locked position.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated January 31, 2007, F.P. Index #0608021A.

**Terms and Conditions:** The above-described unit is accepted on condition that:

1. All uses, figurations, arrangements and functions, application and installations comply with all applicable sections of New York City Building Code, specifically Subchapter 6 (Means of Egress) and with Reference Standard RS 17-3.
2. Installation shall be in accordance with the manufacturer's recommendations, NFPA 72 and UL standard.
3. When installed on fire exits, all of the above model shall be installed in conjunction with a building main fire alarm system, including any tenant fire alarm sub-system as appropriate, and shall be operated by such fire alarm system.
4. The installation of these door locks on the exit doors shall be made electrically Fail Safe (Fail-unlocked) without time delay or a residual magnetism.
5. The above product shall be used only with listed and approved fire alarm equipments and accessories. The compatibility must be specified or determined by a UL test report or the Engineer of Record.
6. Underwriters Laboratories, Inc.'s listing requirements and limitations shall be complied with.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance February 28, 2007

Examined By Donald J. [Signature]