



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 459-04-E

Manufacturer: G. Marks Hardware, Inc., 5300 New Horizons Blvd., Amityville, New York 11701.

Trade Name(s): Marks USA.

Product: Electro Mechanical Mortise Locks.

Pertinent Code Section(s): Subchapters 6 and 17, Reference Standard RS 17.

Prescribed Test(s): UL 1034.

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File R16628, Vol. 1, issued June 25, 2001, revised August 27, 2001. Electrically controlled single-point locks or latches.

Description – Electromechanical Mortise locks connected to fire alarm systems. Model 5EL – Electromechanical Mortise Locksets, Grade 1, ANSI A156.31, UL Listed, 3-Hour Fire Rating.

Ansi #F04 – Electrically Unlocked – 5EL- outside always locked until unlocked by key or electrically energized. Auxiliary latch deadbolts the latch. Inside always open.

Pursuant to “Promulgation of the Rules relating to Materials and Equipment Application Procedures” dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated February 15, 2005, F.P. Index No. 0411039A.

Terms and Conditions: That the above units are accepted on condition that:

1. When installed on fire exits, all of the above models shall be installed in conjunction with a building main fire alarm system, including any tenant fire alarm sub-system as appropriate, and shall be operated by such fire alarm system.
2. The installation of these door locks on the exit doors shall be made electrically Fail-Safe (Fail-unlocked) without time delay or a residual magnetism.
3. Any auxiliary bolt or other devices that prohibits easy access to and egress from buildings shall be prohibited in these locksets.
4. The above products shall be used only with listed and approved fire alarm panels and accessories. The compatibility must be specified or determined by a UL test report or the Engineer of Record.
5. All uses, configurations, arrangements, and functions, application and installations shall comply with all applicable sections of New York City Building Code, including but not limited to Subchapter 6 (Means of Egress) and Reference Standard 17-3.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance September 24, 2005.
Examined by Donald J. [Signature]