



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 465-06-M

**Manufacturer:** 3M Fire Protection Products, 3M Center Bldg. 207-1S-02, St. Paul, MN 55144-1000

**Trade Name(s):** 3M Pass-Through Device

**Product:** Fill, void or cavity material for fire protection

**Pertinent Code Section(s):** 27-345

**Prescribed Test(s):** RS 5-19 (ASTM E-814)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File R9269, Project 05CA15038: September 29, 2005; September 30, 2005; October 3, 2006; October 4, 2005; October 5, 2005; October 6, 2006; October 7, 2005; October 10, 2005; February 3, 2006.

**Description:** Fill, void or cavity material for through penetrations in fire-rated concrete floors, concrete walls, framed floor assemblies, and gypsum wallboard assemblies. The firestop material shall be applied in accordance with UL system numbers listed below achieving the required fire-resistance ratings.

UL System Number	F-Rating (hours)	T-Rating (hours)
CAJ0118	2	1½
CAJ1540	2, 3	0
CAJ2536	2	0, 1½, 2
CAJ3250	3	0
CAJ3252	3	1
CAJ5292	2	¾
CAJ8172	2	0

WL1391	1, 2	0
WL2448	1, 2	0
WL3289	1, 2	0
WL4067	1, 2	0
WL5246	1, 2	0
WL8069	1, 2	0
FC3091	1	1

**Terms and Conditions:** The above-described fill, void or cavity material, used to fill the remaining voids in wall assemblies with the above-described fire protection ratings, is accepted with the following conditions:

1. Electrical trays, cables, mechanical piping or ductwork passing through the assembly shall be installed in accordance with UL system numbers and the manufacturer's application instructions.
2. Suitable support angles and fasteners are required for respective assemblies and shall be provided in accordance with manufacturer's recommendations.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance December 14, 2006

Examined By Sjun Derphidam