



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 468-06-E

**Manufacturer:** Rheem Manufacturing Co., P.O. Box 17010, Fort Smith, AR 72917-7010

**Trade Name(s):** Rheem-Corsaire, Ruud-Zephyr, Weatherking

**Product:** Air-handler and fan coil units

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** UL 1995

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** SA7930, dated November 14, 1994, revised April 26, 2005

**Description:** Air-handler and fan coil units, Model \*\*AHBL-, designed for indoor installation, suitable for use with R-410A condensing unit and heat pumps for upflow, vertical and horizontal positions. Units consist of fin and tube-type evaporator, evaporator blower and safety controls. Units may be provided or employ field-installed electric heaters.

\*\*Models are identical, except for the Trade Name

### Product Covered:

Model No.	Mfr's. Specified Nominal Cooling Capacity (Tons)	Mfr's. Specified Nominal Heating Capacity (BTUH)
17AHBL*	2.0	24,000
21AHBL*	2.5	30,000
21AHBL*	3.0	36,000
24AHBL*	3.5	42,000
24AHBL*	4.0	48,000
25AHBL*	5.0	60,000

\* Denotes additional characters in model numbers.

**Terms and Conditions:** The above-described air handler and fan coil units are accepted for indoor installation under the following conditions:

1. Units shall use only Refrigerant R-410A.
2. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 11/28/06

Examined By Shya or [Signature]