

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner  
MEA 48-00-M  
Report of Material and Equipment Acceptance Division

Manufacturer - Metal-Lite, Inc. 1160 North Blue Gum Avenue, Anaheim, CA 92806.  
Trade Name - "The System".

Product - Slotted deflection fire track for firestopping at the heads of fire rated partitions.

Pertinent Code Section(s) - 27-345.

Prescribed Test(s) - RS 5-19(ASTM 1966, ASTM E814), UL 2079.

Laboratory - Underwriters Laboratories Inc.

Test Report(s) - UL File R18562 and letter dated July 3, 1997.

Description - "The System" provides fireproofing at the heads of fire rated partitions, while allowing for deflection of roof or floor decks. It consists of the "The System" slotted deflection top track ceiling runner. The deck and "The System" slotted deflection top track ceiling runner move in relation to the wall studs. "The System" is approved for use in the following dynamic head -of-wall joint system numbers:

"The System" slotted deflection top track for use in Joint System Nos. HW-D-0027, HW-D-0028, HW-D-0051, and HW-D-0052.

Recommendation - That the above described "The System" be used by itself or in conjunction with other MEA accepted firestop materials to fill the remaining voids in wall or floor/ceiling assemblies with the above described fire protection rating, where there may or may not be electrical trays, cables, mechanical piping or ductwork passing through the assembly, be accepted for use in such assemblies which installed accordance with the manufacturer's application instructions. Suitable support angles and fasteners required for respective assemblies shall be provided in accordance with manufacturer's recommendations. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance MAY 25 2000

Examined By S Derkudam