



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 49-07-E

**Manufacturer:** Marlo Mfg. Co., Inc., 301 Division Street, Boonton, N.J. 07005

**Trade Name(s):** Marlo

**Product:** Refrigeration system (no compressor)

**Pertinent Code Section(s):** 27-771, 27-772

**Prescribed Test(s):** RS 14-6 (UL 471)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File SA 7037, dated June 26, 1996

**Description:** Refrigerated remote, commercial units designed for storage and serving of food. Units are listed below:

Model No.	Voltage	Refrigerant
LBR-7224	115V	401A
LBR-7230	115V	401A

**Terms and Conditions:** The above-described refrigerated units are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided for ventilation into room or space enclosing equipment.

3. The installation shall not obstruct access for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 7/19/07

Examined By Styans. J. S.