



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 492-04-E (Correction)

Note: This publication reflects an addition of item #7 to Terms and Conditions. This supersedes previous approval in its entirety.

Manufacturer: System Sensor, Unincorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): System Sensor

Product: Fire alarm equipment

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89-BCR), Subchapter 17

Test(s): UL 464

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File S4011, Project 04NK17133, Vol. 9, Section 1, issued September 30, 2004

Description: Audible signal device as listed below:

Model No.	Description
PF24	Audible Signal Device

Pursuant to “Promulgation of the Rules relating to Material and Equipment Application Procedures” dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated September 26, 2005, F.P. Index No. 0412022A.

Terms and Conditions: The above units are accepted on condition that:

1. The installation of the above referenced product shall be limited to supplementary use.
2. The above products when installed shall be installed in conjunction with an approved fire alarm system. All uses, configurations, arrangements and functions, application and installations shall comply with all applicable provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3.
3. When installed, the fire alarm panel shall be provided with a disable/enable button/key to silence or activate this above referenced audible device and shall be operated by authorized personnel only. A sign shall be placed clearly indicating as follows: “EXIT POINT DIRECTIONAL SOUNDER ENABLE/DISABLE KEY.”
4. The above referenced audible device(s) shall have a distinct sound from any fire alarm, supervisory and trouble indicating sounds of the fire alarm system. The sound(s) produced by these audible devices shall not interfere/interrupt other notification devices and shall meet the audible requirements as referenced in NFPA 72 Sections 7.4.1.2 & 7.4.2.1 of 2002 Edition.
5. The above referenced products shall be used only with listed and approved control panels and accessories with which compatibility has been determined by Engineer of Record or a UL test report.
6. Installation shall also be in accordance with the manufacturer’s recommendation and UL Standards.
7. The above product should be installed only in those buildings where fire alarm system is installed without a voice evacuation system or any other approved means of voice evacuation plan or communication devices in place.
8. All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.

Final Acceptance March 21, 2007

Examined By Donald [Signature]