



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 492-04-E Vol. 2

Manufacturer: System Sensor, Unicorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): System Sensor

Product: Fire alarm equipment

Pertinent Code Section(s): Subchapter 17 and Reference Standard RS 17

Prescribed Test(s): UL 464

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File S4011, Project 04NK`17133, issued September 30, 2004, revised October 18, 2006

Description: Audible signal device, Model #PF24V

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated November 28, 2006, F.P. Index #0611010.

Terms and Conditions: The above unit is accepted on condition that:

1. The installation of unit shall be limited to supplementary use. All building(s) where the unit is installed shall be in full compliance with the Egress/Exit requirements, as per New York City Building Code.

2. The unit should be installed only in those building(s) where fire alarm system is installed without a voice-evacuation system or any other approved means of voice-evacuation plan or communication devices in place.
3. The unit shall be installed in conjunction with an approved fire alarm system.
4. All uses, configurations, arrangements and functions, application and installations comply with all applicable provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard RS 17-3.
5. When installed, the unit shall be arranged in a manner that the audible signal device shall be activated after a time delay of not less than 60 seconds of any fire alarm.
6. When installed, the fire alarm panel shall be provided with a disable/enable button/key to silence or activate the audible device, and shall be operated by authorized personnel only. A sign shall be placed clearly indicating, as follows:

“EXITPOINT DIRECTIONAL SOUNDER ENABLE/DISABLE KEY”.

7. The unit shall be used only with listed and approved control panels and accessories with which compatibility has been determined by Engineer of Record or a UL report.
8. Manufacturer’s installation procedures and limitations shall be complied with.
9. Underwriters Laboratories, Inc.’s listing requirements shall be complied with.
10. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance March 15, 2007

Examined By  