

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner

MEA 50-00-E

Report of Material and Equipment Acceptance Division

Manufacturer– Denso Sales California Inc., 3900 Via Oro Avenue, Long Branch, CA 90810.

Trade Name(s) – MoveinCool.

Product – Portable air conditioners.

Pertinent Code Section(s) - 27-770, 27-777.

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – File SA 10472, dated May 4, 1999.

Description – Water or air-cooled portable air conditioners, designed for indoor installation. R-22 is the refrigerant used for the system. Unit consists of air or water-cooled condenser and safety controls. Units, with model numbers and nominal cooling capacities are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity (BTUH)
Classic Plus 26	26,000

Recommendation - That the above described portable air conditioners, be accepted utilizing refrigerant R-22, under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance Feb. 25, 2000

Examined By [Signature]