



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 520-06-E

Manufacturer: Canadian Heating Products Inc., 27342 Gloucester Way, Langley, BC V4W 4A1, Canada

Trade Name(s): Montigo

Product: Direct-vent, gas fireplace heater

Pertinent Code Section(s): 27-800, 27-825

Prescribed Test(s): RS 14-6 (ANSI Z21.88)

Laboratory: CSA International

Test Report(s): CSA Approval Certificate 1554457, Project 1717702, dated June 19, 2006

Description: The L-series DF (N,L)(I,A) is a direct-vent, gas fireplace with a linear-style burner. This fireplace can be converted to both a Top Vent and Rear Vent application.

- L38DF – Top or Real Vent, with Millivolt Pilot
- L38DF-I – Top or Rear Vent, Intermittent Pilot (HSI)
- L38DF-A – Top and Rear Vent, with Battery Back-up System

Product Covered:

Model No.	Maximum Rating (BTUH)	Minimum Rating (BTUH)
L38DF	25,000	20,000

Terms and Conditions: The above-described heater is accepted for operation under the following conditions:

1. Unit shall use natural gas only.
2. Unit shall be installed by a licensed plumber only, who shall ensure that installation is provided with required unobstructed vent-opening and that all Gas Company requirements for this type of installation are strictly enforced.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 2/9/07

Examined By Shyam P