



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 524-06-E

**Manufacturer:** Lennox Hearth Products, 1110 W. Taft Avenue, Orange, CA 92865

**Trade Name(s):** Lennox

**Product:** Direct-vent gas fireplace

**Pertinent Code Section(s):** 27-855, 27-884

**Prescribed Test(s):** RS 14-6 (ANSI Z21.88)

**Laboratory:** Omni Test Laboratories, Inc.

**Test Report(s):** Certificate No. 16-F-05-8 dated March 11, 2003

**Description:** Direct-vent gas fireplaces.

Model No.	Input (BTU/H)
EDV3530, SDDV-35	27,000
EDV4035, SDDV-40	30,000
EDV4540	33,000

**Terms and Conditions:** The above-described vents are accepted under the following conditions:

1. These gas vents shall be used in accordance with the New York Building Code for the venting of natural gas-fired appliances.
2. These gas vents shall be labeled to read, "This gas vent is for equipment which burns gas only. Do not connect to incinerator or solid or liquid fuel-burning equipment."
3. Vents must be installed and used in accordance with instructions provided by the manufacturer, the New York City Building Code and Reference Standard 15-13.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 8/7/07

Examined By 