



NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### **MEA 540-06-E**

**Manufacturer:** Alto-Shaam, Inc., W164 N9221 Water Street,  
Menomonee Falls, WI 53052

**Trade Name(s):** Alto-Shaam

**Product:** Electric convection ovens

**Pertinent Code Section(s):** 27-787, 27-792

**Prescribed Test(s):** RS 14-6 (UL 197)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File U52279, dated June 8, 1998

**Description:** These are electric convection ovens. Unit is comprised of compressor, electric door and thermal windows, 5 kw heating element and electronic controls with food probe

**Product Covered:**

Convection Oven: ASC-2E; ASC-4E, ASC-6E

**Terms and Conditions:** The above electrical convection ovens are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical, Building and Fire Codes requirements.
2. Cooking equipment shall be installed under hoods that vent to the outside, shall comply with Reference Standard RS-13 requirements of the New York City Building Code and shall have a fire-suppression system complying with Reference Standards RS 13-2 and RS 13-3 with open heads and capable of simultaneous discharge and manual release. The fire-suppression system exclusively used for cooking equipment shall be filed with the Building Department and examined and approved by the Fire Department.
3. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
4. The installation shall not obstruct required access for operation and servicing.
5. For grease removal, suitable baffle-type grease filters, MEA-accepted, shall be installed.
6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
7. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
8. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 3/6/07

Examined By Shyam. Arora