



NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 580-06-E Vol. 3

**Manufacturer:** Gentex Corporation, 10985 Chicago Drive, Zeeland, MI 49464

**Trade Name(s):** Gentex

**Product:** Ceiling- and wall-mounted speakers, speaker/strobe for fire protective signaling systems, and Horn for low-frequency evacuation signals  
MEA Index #280 – Fire Alarm Equipment

**Pertinent Code Section(s):** Subchapter 17 and Reference Standard RS 17

**Prescribed Test(s):** UL 464, UL 1480, UL 1971

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File S5182, Project 01NK40776, dated January 30, 2002 and revised July 17, 2007.  
UL File S3406, Project 97NK15075/00NK32815 issued June 17, 1997 and revised February 27, 2001.

**Description:** Fire alarm equipment.

**SSPKCLP** series consisting of SSPKCLPR, SSPKCLPW, SSPK24CLPR and SSPK24CLPW are low-profile ceiling and wall-mounted fire alarm speakers and speaker/strobes with white faceplate listed for 25 and 70.7 Volt, with 1/8 to 4 Watt taps.

**SSPKWLP** series consisting of SSPKCLPR, SSPKCLPW, SSPK24WLPR and SSPK24WLPW, SSPK24-15/75WLPR and SSPK24-15/75WLPW are low-profile wall-mounted fire alarm speaker/strobes with red and white faceplates listed for 25 and 70.7 Volt, with 1/8 to 4 Watt taps.

**GEH12-R/-W** are low-profile evacuation horns with red and white faceplates.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections (letter dated March 4, 2008, F.P. Index #0802044).

**Terms and Conditions:** The above-described fire alarm devices are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with the provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard 17-3 & 17-5. Further, the installation of these fire alarm devices shall be in accordance with the manufacturer's recommendations, NFPA 72 and UL standards 464, 1480 and 1971.
2. The above product shall be used only with compatible, listed and approved fire alarm equipment.
3. Underwriters Laboratories Inc.'s listing requirements and limitations shall be complied with.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 18, 2008  
Examined By Donald [Signature]