



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 582-06-E

Manufacturer: System Sensor, Unicorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): System Sensor

Product: Fire alarm equipment - mounting plates

Pertinent Code Section(s): RS 17-3, Subchapter 17

Prescribed Test(s): UL 464, UL 1971

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): S4011, issued October 31, 2005, revised June 13, 2006

Description: Model No. MP120K, 120VAC Adaptor mounting plate.

The MP120K can only be used for non-synchronous applications. It powers all two-wire indoor and outdoor SpectrAlert Advance Series horns, strobes, horn/strobes, chimes & chime/strobes (reference MEA 452-05-E). Electrical rating: 96-132 VAC, 150mA maximum. Operating temperature range: -40° F to 151° F (-40° C to 66° C).

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated December 4, 2006, F.P. Index #0611054.

Terms and Conditions: The above unit is accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with the provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard 17-3.
2. The installation shall also be in accordance with manufacturer's recommendation, NFPA 72 and UL standards.
3. The product shall be used only with approved/accepted compatible notification devices.
4. Underwriters Laboratories, Inc.'s listing requirements and limitations shall be complied with.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance January 9, 2007
Examined By Donald [Signature]